

15ppb action limit 250ml plus WM ELAP						
Sample ID	Sample Location	Collection Date	Initial/Post Remediation	Lead Results ug/L(ppb)	Lab Report Reciept Date	Action Taken
R-1 PB	rm 1 porcelain bubbler, PB	3/11/2020	Initial	8.5	4/3/2020	
R-1 S1	rm 1 toilet room sink	3/11/2020	Initial	10.7	4/3/2020	
R-1 S2	rm1 sink in classroom counter	3/11/2020	Initial	2.2	4/3/2020	
R-2 PB	rm 2 porcelain bubbler, PB	3/11/2020	Initial	15	4/3/2020	
R-2 S1	rm 2 toilet room sink	3/11/2020	Initial	9.3	4/3/2020	
R-2 S2	rm 2 sink in classroom counter	3/11/2020	Initial	3.4	4/3/2020	
R-3 PB	rm 3 porcelain bubbler, PB	3/11/2020	Initial	5	4/3/2020	
R-3 S1	rm 3 toilet room sink	3/11/2020	Initial	4.3	4/3/2020	
R-3 S2	rm 3 sink in classroom counter	3/11/2020	15.8/9.8	9.8	4/3/2020	maint
R-4 PB	rm 4 porcelain bubbler, PB	3/11/2020	Initial	1.2	4/3/2020	
R-4 S1	rm 4 toilet room sink	3/11/2020	Initial	<5.2	4/3/2020	
R-4 S2	rm 4 sink in classroom counter	3/11/2020	Initial	1.8	4/3/2020	
NO- S1	rm 7 Nurse/Health Office sink	3/11/2020	Initial	1.3	4/3/2020	
NO- S2	Health Office sink	3/11/2020	Initial	5.1	4/3/2020	
R-8 S	rm 8 sink OT/PT	3/11/2020	Initial	12.5	4/3/2020	
WF1	hall water fountain across rm 8	3/11/2020	Initial	<1.1	4/3/2020	
BF 1	hall bottle filler across rm 8	3/11/2020	Initial	<1.1	4/3/2020	
Kit - S1	rm 6 Dbl Bwl kitchen sink,to left	3/11/2020	Initial	7.9	4/3/2020	
Kit - S2	rm 6 3Bay Kitchen sink, to right	3/11/2020	Initial	8.9	4/3/2020	
GTR S1	GTR Sink closest door, X lounge	3/11/2020	Initial	<1.1	4/3/2020	
GTR S2	GTR Sink farthest door,X lounge	3/11/2020	Initial	<1.1	4/3/2020	
BTR S1	BTR Sink closest door X lounge	3/11/2020	Initial	<1.1	4/3/2020	
BTR S2	BTR Sink farthest door X lounge	3/11/2020	Initial	<1.1	4/3/2020	
R-14 PB	rm 14 porcelain bubbler, PB	3/11/2020	Initial	2.1	4/3/2020	
R-14 S	rm 14 sink	3/11/2020	20.9/10.5	10.5	4/3/2020	maint
R-15 PB	rm 15 porcelain bubbler, PB	3/11/2020	Initial	2.6	4/3/2020	
R-15 S1	rm 15 sink on left cabinet wall	3/11/2020	45.6/15.6	1.8	4/3/2020	Maint
R-30 MB	rm 30 metal bubbler, MB	3/11/2020	Initial	1	4/3/2020	
R-30 S1	rm 30 sink	3/11/2020	Initial	<10.3	4/3/2020	
R-30 S2	rm 30 sink	3/11/2020	Initial	1.3	4/3/2020	
R-29 MB	rm 29 metal bubbler, MB	3/11/2020	Initial	<1.1	4/3/2020	
R-29 S1	rm 29 sink on left cabinet wall	3/11/2020	Initial	<1.1	4/3/2020	
R-29-S2	rm 29 sink on back cabinet wall	3/11/2020	Initial	1	4/3/2020	
R-28 MB	rm 28 metal bubbler, MB	3/11/2020	Initial	1.2	4/3/2020	
R-28 S1	rm 28 sink left cabinet wall	3/11/2020	Initial	1.2	4/3/2020	
R-28 S2	rm 28 sink back cabinet wall	3/11/2020	Initial	3.4	4/3/2020	
WF2	hall dbl wtr ftn left side by R-28		Not Working	at time of	sampling	
WF3	hall dbl wtr ftn right by R-27		Not Working	at time of	sampling	
R-27 MB	rm 27 metal bubbler, MB	3/11/2020	Initial	1.3	4/3/2020	
R-27 S1	rm 27 sink on right cabinet wall	3/11/2020	Initial	1.9	4/3/2020	

Lead in DW Sample Points = 54 total
 Tim Gilbert, GST BOCES

**Odessa Montour BC Kate
 Lead 2020 Sample Plan**

**10NYCRR (Subpart 67-4)
 Yellow Highlight = >15ppb**

R-27 S2	rm 27 sink on back cabinet wall	3/11/2020	32.3/.15	0.15	4/3/2020	maint
R-26 MB	rm 26 metal bubbler, MB	3/11/2020	Initial	1	4/3/2020	
R-26 S1	rm 26 sink right cabinet wall	3/11/2020	Initial	1.2	4/3/2020	
R-26 S2	rm 26 sink back cabinet wall	3/11/2020	Initial	2.4	4/3/2020	
R-20 PB	rm 20 porcelain bubbler, PB	3/11/2020	Initial	10.3	4/3/2020	
R-20 S	rm 20 sink	3/11/2020	Initial	1.7	4/3/2020	
R-19 PB	rm 19 porcelain bubbler, PB	3/11/2020	Initial	12.6	4/3/2020	
R-19 S	rm 19 sink	3/11/2020	Initial	8.3	4/3/2020	
R-18 PB	rm 18 porcelain bubbler, PB	3/11/2020	Initial	6.8	4/3/2020	
R-18 S	rm 18 sink	3/11/2020	Initial	12.8	4/3/2020	
R-17 PB	rm 17 porcelain bubbler, PB	3/11/2020	Initial	4	4/3/2020	
R-17 S	rm 17 sink	3/11/2020	15.9/.63	0.63	4/3/2020	maint
R-16PB	rm 16 porcelain bubbler, PB	3/11/2020	Initial	6.2	4/3/2020	
R-16 S	rm 16 sink	3/11/2020	Initial	10.1	4/3/2020	

15ppb action limit 250ml plus WM ELAP						
Sample ID	Sample Location	Collection Date	Initial/Post Remediation	Lead Results ug/L(ppb)	Lab Report Reciept Date	Action Taken
R-31 S	room 31 sink	3/11/2020	35.2/.71	0.71	4/3/2020	Maint
R-30 S	room 30 sink	3/11/2020	Initial	4.3	4/3/2020	
R-29 S	room 29 sink	3/11/2020	Initial	14	4/3/2020	
R-27 S	room 27 sink	3/11/2020	19.4/.34	0.34	4/3/2020	
R-25 B	room 25 bubbler	3/11/2020	Initial	14	4/3/2020	
R-25 S	room 25 sink	3/11/2020	Initial	15	4/3/2020	
R-22 S	library room 22 sink	3/11/2020	Initial	12.4	4/3/2020	
R-21 S	sink	3/11/2020	44.5/.52	0.52	4/3/2020	Maint
WF 1	hall WF across boys/girls btrms	3/11/2020	Initial	<1.0	4/3/2020	
Caf WF	Cafeteria Water Fountain	3/11/2020	Initial	<1.0	4/3/2020	
Caf BF	Cafeteria Bottle Filler	3/11/2020	Initial	<1.1	4/3/2020	
WF 2	hal WF across from main off	3/11/2020	Initial	1.4	4/3/2020	
NO-S1	toilet room sink in nurses off	3/11/2020	Initial	3.8	4/3/2020	
NO-S2	exam room sink in nurses off	3/11/2020	Initial	1.2	4/3/2020	
R-12 S	room 12 sink	3/11/2020	17.5/118	3.7	4/3/2020	replaced
R-10 B	room 10 bubbler	3/11/2020	Initial	<1.0	4/3/2020	
R-10 S	room 10 sink	3/11/2020	Initial	2	4/3/2020	
R-8 B	room 8 bubbler	3/11/2020	Initial	2.2	4/3/2020	
R-8 S	room 8 sink	3/11/2020	Initial	<1.0	4/3/2020	
R-7 B	room 7 bubbler	3/11/2020	Initial	1.5	4/3/2020	
R-7 S	room 7 sink	3/11/2020	Initial	<1.0	4/3/2020	
R-6 B	room 6 bubbler	3/11/2020	Initial	<1.0	4/3/2020	
R-6 S	room 6 sink	3/11/2020	Initial	1.9	4/3/2020	
R-5 B	room 5 bubbler	3/11/2020	Initial	4.3	4/3/2020	
R-5 S	room 5 sink	3/11/2020	Initial	2.7	4/3/2020	
R-4 B	room 4 bubbler	3/11/2020	Initial	5.2	4/3/2020	
R-4 S	room 4 sink	3/11/2020	Initial	2.1	4/3/2020	
R-3 B	room 3 bubbler	3/11/2020	Initial	2.7	4/3/2020	
R-3 S	room 3 sink	3/11/2020	Initial	6.8	4/3/2020	
R-2 S	room 2 sink	3/11/2020	Initial	1.1	4/3/2020	
R-1 B	room 1 bubbler	3/11/2020	Initial	1.6	4/3/2020	
R-1 S	room 1 sink	3/11/2020	Initial	2.2	4/3/2020	

15ppb action limit 250ml plus WM ELAP						
Sample ID	Sample Location	Collected Date	Initial/Post Remediation	Results ug/L(ppb)	Rec'd Rept. Date	Action Taken
404 S	R 404 2 bay sink			1.1	4/3/2020	
405 S	R 405 sink by door+elec panel	3/11/2020	58.2/.10	0.1	4/3/2020	maint
BLR1 S	boys locker room sink by urinal	3/11/2020		2.2	4/3/2020	
409 B	room 409 sink	3/11/2020		13.4	4/3/2020	
409 S	room 409 bubbler	3/11/2020		6.2	4/3/2020	
411 S1	411A - sink closest to door	3/11/2020		9	4/3/2020	
411 S2	411A -back sink back S1	3/11/2020	20/11.1	11	4/3/2020	maint
411 S3	rm next 411A sink closest door	3/11/2020		2	4/3/2020	
411 S4	rm next 411A sink back S3	3/11/2020		4.2	4/3/2020	
GLR1 S	girls locker room sink	3/11/2020		2.2	4/3/2020	
BTR S	boys toilet rm sink X Gym+GLR	3/11/2020	29.9/.14	0.14	4/3/2020	maint
WF 1	hall WF by BTR and GTR	3/11/2020		<1	4/3/2020	
GTR S	girls toilet rm sink X Gym+GLR	3/11/2020		13.7	4/3/2020	
309 S	room 309 sink	3/11/2020		13.9	4/3/2020	
Hall WF		3/11/2020		1	4/3/2020	
Hall BF		3/11/2020		1	4/3/2020	
BLR WF	boy lock Water Ftn, Lft HS Gym	3/11/2020		1	4/3/2020	
GLR WF	girl lock Water Ftn, Rt HS Gym	3/11/2020		1.3	4/3/2020	
GTR3-S	girls TR sink, across rm 151	3/11/2020		1.6	4/3/2020	
WF ADA	left ADA Water Ftn, adj gym	3/11/2020		1	4/3/2020	
WF2	upper right Water Ftn, adj gym	3/11/2020		1	4/3/2020	
BTR3-S	boys TR sink, next to room 152	3/11/2020		2.8	4/3/2020	
kit S1	kitchen double bowl sink by ice	3/11/2020	60.1/1	1	4/3/2020	Replaced
Kit Ice	kitchen ice machine	3/11/2020		<1	4/3/2020	
Kit S2	kitchen island sink by Pot	3/11/2020		10	4/3/2020	
Kit Pot	large kitchen Pot	3/11/2020		7.2	4/3/2020	
Kit Stm	large kitchen steamer	3/11/2020		<1	4/3/2020	
Caf WF	water fountain in cafeteria	3/11/2020		<1	4/3/2020	
Caf BF	bottle filler in cafeteria	3/11/2020		<1	4/3/2020	
112 S1	room 112 sink island by door	post?	posted		4/3/2020	
112 S2	room 112 sink backwall	3/11/2020	posted		4/3/2020	
Gtr S1	Gtr sink X off.116, farthest door	3/11/2020		0.13	4/3/2020	
Gtr S2	closest door	3/11/2020		0.13	4/3/2020	
WF 3	hall WF by r105	3/11/2020		<1	4/3/2020	
WF 4	hall WF by r103	3/11/2020		<1	4/3/2020	
102 S	toilet room sink	Post?	posted			
100 S1		Post?	posted			
100 S2		Post?	posted			
2FLGTrS	2nd flr GTR Sink by room 200	3/11/2020		0.13	4/3/2020	
2flBtrS1	2nd flr Btr by 201, Sink by window	3/11/2020		4	4/3/2020	
2flBtrS2	2nd flr Btr by 201, Sink close to dr	3/11/2020		<1.0	4/3/2020	
WF 5	2nd flr hall WF upper right by 201	3/11/2020		<1	4/3/2020	

Lead in DW sample pts = 55 total
 Tim Gilbert, GST BOCES

Odessa Montour High School
 Lead 2020 Sample Plan

10NYCRR (Subpart 67-4)
 Yellow Highlight = >15ppb

WF 6	2nd flr hall WF lowADA left by 201	3/11/2020		<1	4/3/2020	
WF 7	2nd flr hall WF by room 207	3/11/2020		1.3	4/3/2020	
207 S1	sink closest door on left	3/11/2020		2.5	4/3/2020	
207 S2	inner hall wall sink right	3/11/2020		10.2	4/3/2020	
207 S3	back wall sink left side	3/11/2020		3.7	4/3/2020	
207 S4	back wall sink right by outer wall	3/11/2020		3.3	4/3/2020	
2fGtr S1	2nd flr Gtr sink by r200, by window	3/11/2020	31.2/<1	31.2	4/3/2020	maint
2fGtr S2	2nd flr Gtr sink by r200, door side	3/11/2020		5.5	4/3/2020	
211c S	library prep room 211c sink	3/11/2020		6.6	4/3/2020	
220 S	r220 sink in bathroom closest door	3/11/2020		1.2	4/3/2020	
2fBtr S1	2nd flr Btr sink by r212, by window	3/11/2020	16.6/4.4	16.6	4/3/2020	maint
2fBtr S2	2nd flr Btr sink by r212, door side	3/11/2020		4.1	4/3/2020	
WF 8	2nd flr hall WF by room 214	3/11/2020		<1	4/3/2020	
CSBtrS1	Concessions boys bath sink left	10/16/2020	20.4/3.7	3.7	4/3/2020	maint
CSBtrS2	Concessions boys bath sink right	10/16/2020		10.2	4/3/2020	
CSGtrS1	Concessions girls bath sink left	10/16/2020		10.9	4/3/2020	
CSGtrS2	Concessions girls bath sink right	10/16/2020	20/4.6	4.6	4/3/2020	maint
CS-S	Concessions Main Sink	10/16/2020		0.76	4/3/2020	